



Montageanleitung

Einstrahl-/Mehrstrahlzähler/Patronenzähler

Installation manual single/multi jet meters/cartridge meters

Allgemeine Hinweise

- Wassermessgeräte sind Präzisionsgeräte. Vor Stößen und Erschütterungen schützen. Frostfrei lagern.
- Die Dichtflächen sind mit Gewindeschutzkappen versehen und vor Beschädigung geschützt.
- Kontrollieren Sie vor Montagebeginn: - dass die Dichtflächen eben und frei von
- Beschädigungen wie Kerben, Furchen o.ä. sind.
 - alle Angaben auf dem Zifferblatt lesbar sind*.
 - der Zähler in Bauart, Größe, Temperaturbereich und Druckstufe zur Einbaustelle passt.
- Bei belastetem Wasser empfehlen wir, Schmutzfänger in die Zuleitung vor dem Zähler einzubauen.
- Den Zähler möglichst am tiefsten Punkt der Installation sowie frostsicher einbauen zur Vermeidung von Luftansammlungen und Beschädigungen.
- Der Wasserzähler muss frei von mechanischen Spannungen montiert werden.
- Wasserzähler müssen im Betrieb vollständig mit Wasser gefüllt sein – bei Nassläufern auch das Zählwerk!
- Der Zähler muss durch geeignete Maßnahmen vor Druckschlägen in der Rohrleitung geschützt werden.
- Bei Frostgefahr die Anlage absperren und vollständig entleeren (auch den Zähler!), notfalls den Zähler ausbauen.
- Der Zähler muss jederzeit gut zugänglich und ablesbar sein, inkl. aller Angaben auf dem Zifferblatt.
- Wir empfehlen, die Anschlussstellen an die Rohrleitung mit einer Benutzersicherung gegen unbefugte Demontage zu sichern. Die Sicherung sollte nicht ohne sichtbare Beschädigung entfernt oder gelockert werden können.
- Die Montage sollte nur von qualifiziertem Fachpersonal durchgeführt werden.

*Durchflussangaben abhängig von jeweiliger Nenngröße

General notes

- Watermeters are precision instruments. Protect against shock and vibration. Store frost-free.
- The sealing surfaces are equipped with thread protection caps, and thus protected from damage.
- Check and ensure before beginning the installation:
 - That the sealing faces are flat and free from damage such as notches, grooves, etc..
 - That all indications on the dial are readable*.
 - The meter fits in type, size, temperature and pressure rating to the installation and metering point.
- With polluted or loaded water we recommend that filters or strainers in the inlet must be installed upstream of the meter.
- The meter should always be installed at the lowest possible point of the piping as well as frost protected, to prevent the accumulation of air and damages.
- The watermeter must be installed into the pipeline free of any of mechanical forces or tensions.
- Watermeters must be operating completely filled with water - for wet dial meters this includes also the counter!
- The meter must be protected with appropriate measures against pressure shocks in the pipeline.
- When there is danger of frost, empty completely and shut off the installation (including the meter), if necessary, dismantle the meter.
- The meter must always be easily accessible and legible, including all indications on the dial.
- We recommend that the installation points on the pipeline should be secured with a seal against unauthorized dismantling. The seal should not be removable or loosened without visible damage.
- The installation has to be done by qualified professional personnel.

*Data regarding the flow rates are depending on the respective nominal size.

Konformitätserklärung

Hiermit erklärt ZENNER International GmbH & Co. KG, dass das Produkt mit einer der Prüfbescheinigungsnummern DE-06-MI001-PTB005, DE-06-MI001-PTB006, DE-07-MI001-PTB009, DE-08-MI001-PTB016, DE-08-MI001-PTB017, DE-07-MI001-PTB010 oder CH-MI001-10040 den wesentlichen Anforderungen der EG Richtlinie 2004/22/EG (Messgeräte richtlinie) entspricht.

Hiermit erklärt ZENNER International GmbH & Co. KG, dass das Produkt für Fernauslesung RDM mit der Anwendung Drahtlose Kommunikation den wesentlichen Anforderungen der EG Richtlinie 1999/5/EG (R&TTE) entspricht. Aktuelle Informationen finden Sie unter www.zenner.com

Montage:

1. Montageanleitung sorgfältig bis zum Schluss durchlesen!
2. Absperrorgane vor und hinter dem Zähler schließen.
3. Einbaustelle druckentlasten.
4. Vorhandenen Zähler oder Passstück ausbauen.
5. Nur neues und einwandfreies Dichtmaterial verwenden.
6. Dichtflächen auf Beschädigungen kontrollieren.
7. Neuen Zähler fließrichtungs- und lagerichtig einbauen. Darauf achten, dass die Dichtungen nicht verrutschen, herausfallen oder beschädigt werden.
8. Überwurfmutter aufschrauben und festziehen.
9. Absperrorgane langsam öffnen – Druckschläge vermeiden.
10. Einbaustelle auf Dichtheit prüfen. Das Ziffernblatt und die Konformitäts-/Metrologiekennzeichen müssen jederzeit gut ablesbar sein.

Zusatzhinweise für Kunststoffzähler Montage:

- Um einen spannungsfreien Einbau zu gewährleisten, empfehlen wir die Verwendung einer Wasserzähler-Einbaugarnitur (WZAG).
- Empfohlenes Anzugs-Drehmoment bei Anschlussverschraubungen: Min. 20Nm bis Max. 30Nm.

Declaration of conformity

ZENNER International GmbH & Co. KG declares that the product with the number of one of the EC type-examination certificates DE-06-MI001-PTB005, DE-06-MI001-PTB006, DE-06-MI001-PTB009, DE-08-MI001-PTB016, DE-08-MI001-PTB017 or DE-07-MI001-PTB010 or CH-MI001-10040-complies with the essential requirements of the EC directive 2004/22/EC (Measuring instruments directive). ZENNER International GmbH & Co. KG hereby declares that the product for Remote Metering RDM with the application Wireless Communications complies with the essential requirements of the EC directive 1999/5/CE (R&TTE). The most up-to-date information about this product can be found at www.zenner.com

Installation:

1. Read these instructions carefully right up to the end!
2. Close valves upstream and downstream of the meter.
3. Release pressure at the installation point.
4. Dismount existing meters or meter blanks.
5. Use only new and flawless sealing material.
6. Check the seal face for damage.
7. Install the new meter according to the correct flow direction and installation position. Ensure that the sealing joints do not fall out, or are being damaged.
8. Screw the connection nuts and tighten them.
9. Open valves carefully and avoid pressure shocks.
10. Check installation for leakage. The dial and the indications regarding the conformity /metrology must be visible and readable at any time.

Additional instructions for installation of plastic meter:

- In order to guarantee a stress-free installation, we recommend the use of a water meter installation bracket (WZAG).
- Recommended tightening torque for the connectors: min. 20Nm up to max. 30Nm.

ZENNER International GmbH & Co. KG

Römerstadt 4 Telefon +49 681 99 676-30
D-66121 Saarbrücken Telefax +49 681 99 676-3100

E-Mail info@zenner.com
Internet www.zenner.com

ZENNER
Alles, was zählt.